



## CITY OF MILLBRAE \* STANDARD PLANS

NO.	REVISIONS		DATE	SANITARY SEWER LATERAL CONNECTION				APPROVED
DRAWN	CK	CHECKED	NT	DATE	03/2024	SCALE	NTS	SHEET
								1 OF 2
								DWG. NO. <b>S-1.1</b>

City Engineer

GENERAL NOTES:

1. REFER TO STANDARD S-10, FOR BACK-FLOW PREVENTION DEVICE REQUIREMENTS.
2. REFER TO STANDARDS R-1 AND R-8, FOR CONCRETE REPLACEMENT AND DEMOLITION REQUIREMENTS.
3. REFER TO STANDARD R-9, "UTILITY TRENCH DETAIL", FOR BACKFILL AND TEE CUT REQUIREMENTS.
4. THE SEWER LATERAL FROM THE BACK OF WALK TO THE BUILDING SHALL BE CONSTRUCTED PER BUILDING DEPARTMENT REQUIREMENTS.
5. IN SIDEWALK, USE CHRISTY TYPE F1 VALVE BOX WITH F8D LID OR EQUAL. IN DRIVEWAY, USE CHRISTY TYPE G5 TRAFFIC BOX WITH G5C LID OR EQUAL. THE LID SHALL BE MARKED "SEWER".
6. WHERE NO SIDEWALK EXISTS, THE CLEAN-OUT BOX SHALL BE SET NO MORE THAN 3 FEET BEHIND THE CURB AND A MINIMUM OF 1-1/2" ABOVE THE PLANTED AREA, OR IN A SIDE-YARD WITHIN 2-1/2' OF THE SEWER MAIN.
7. LATERAL SIZE SHALL BE MINIMUM 4" FOR RESIDENTIAL AND 6" FOR MULTI-FAMILY OR COMMERCIAL PROPERTIES.
8. WHEN A CONNECTION IS MADE TO THE CITY SYSTEM, THE CONTRACTOR SHALL MATCH THE EXISTING MATERIAL OF THE SEWER MAIN.
9. LATERALS SHALL NOT TEE INTO THE CITY MAIN. A STANDARD WYE CONNECTION IS REQUIRED.
10. SIDEWALK CLEAN-OUT SHALL BE CONSTRUCTED OF FUSED SDR-17 HIGH DENSITY POLYETHYLENE.

**CITY OF MILLBRAE \* STANDARD PLANS**

NO.	REVISIONS		DATE	SANITARY SEWER LATERAL CONNECTION				APPROVED <hr/> City Engineer
DRAWN	CK	CHECKED	NT	DATE	SCALE	NTS	SHEET	DWG. NO.
				03/2024			2 OF 2	<b>S-1.2</b>