



## NOTES:

1. IN CASE OF NO SIDEWALK, METER BOX TO BE LOCATED WITHIN THREE (3) FEET OF PROPERTY LINE.
2. SENSUS SR II TOUCH READ (TR/PL) WATER METER WITH 100 CUBIC FOOT REGISTER FURNISHED BY CUSTOMER.
3. CHRISTY BOX B16P (MINIMUM) WITH 1-3/4" HOLES FOR READING METER.
4. 36" MIN. DEPTH IN PAVED AREAS 24" MIN. DEPTH IN UNPAVED AREAS.

## CITY OF MILLBRAE \* STANDARD PLANS

NO.	REVISIONS		DATE	WATER SERVICE CONNECTION	APPROVED
DRAWN	CK	CHECKED	NT	DATE 03/2024	SCALE NTS
					SHEET 1 OF 1
					DWG. NO. <b>W-1</b>
					City Engineer