



## NOTES:

1. ENCLOSURE SHALL BE FIELD MEASURED AND FABRICATED AFTER BACKFLOW PREVENTER HAS BEEN INSTALLED.
2. THERE SHALL BE 2" MIN. CLEAR TOP AND 12" ALL SIDES BETWEEN ENCLOSURE AND ANY PIPE AND FITTINGS.
3. ALL METAL SHALL BE STAINLESS STEEL. GRIND WELDS SMOOTH.
4. INSTALL EIGHT 9/16" X 4" STAINLESS STEEL EXPANSION HOLD DOWN BOLTS 4" TO 8" FROM CORNER.
5. BACKFLOW PREVENTER TO BE INSTALLED SO THAT TEST PETCOCKS FALL TOWARD OPENABLE SIDES.
6. FOR PCC SLAB, AB, AND PEA GRAVEL PLACEMENT REFER TO BACKFLOW PREVENTER ASSEMBLY, DWG. W-4.
7. 3-1/4" STAINLESS STEEL HINGES (6 TOT.) WELD TO FRAME 6" FROM EACH END AND AT CENTER (USE NON-REMOVABLE HINGE PIN).

## CITY OF MILLBRAE \* STANDARD PLANS

NO.	REVISIONS		DATE	BACKFLOW PREVENTER CAGE ASSEMBLY	APPROVED  City Engineer
DRAWN	CK	CHECKED	NT	DATE 03/2024	SCALE NTS
					SHEET 1 OF 1
					DWG. NO. <b>W-5</b>