



GENERAL NOTES:

1. REFER TO STANDARD W-2 FOR HYDRANT INSTALLATION DETAILS.
2. PLACE FIRE HYDRANT BEHIND SIDEWALK WHERE SIDEWALK AND CURB ARE A TOTAL OF 6 FEET WIDE OR LESS.
3. FIRE HYDRANT AND PAD MUST BE WITHIN CITY RIGHT-OF-WAY OR P.U.E.
4. DO NOT LOCATE STREET LIGHT OR TREE AT SAME PROPERTY LINE JUNCTION AS FIRE HYDRANT.
5. FIRE HYDRANT SHALL BE NUMBERED.
6. FIRE HYDRANT SHALL BE COLOR CODED ACCORDING TO PUBLIC WORKS SPECIFICATIONS.

CITY OF MILLBRAE * STANDARD PLANS

NO.	REVISIONS		DATE	FIRE HYDRANT LOCATION	APPROVED			
DRAWN	CK	CHECKED	NT	DATE 03/2024	SCALE NTS	SHEET 1 OF 1		
					DWG. NO.	W-9		