



City of Millbrae

CALIFORNIA RESIDENTIAL CODE SMOKE AND CARBON MONOXIDE ALARMS REQUIREMENTS

Prior to scheduling a Final Inspection, this form shall be completed and submitted to the Building Inspector via email at ptech@ci.millbrae.ca.us

SMOKE ALARMS R314

SMOKE ALARMS SHALL BE INSTALLED IN THE FOLLOWING LOCATIONS:

1. In each sleeping room.
2. Outside each separate sleeping area in the immediate vicinity of the bedrooms.
3. On each additional story of the dwelling, including basements, habitable attics, and uninhabitable attics.
4. In hallway and in room open to the hallway in dwelling units where ceiling height of a room open to a hallway serving bedrooms exceeds that of the hallway by 24 inches or more

CARBON MONOXIDE ALARMS R315

CARBON MONOXIDE ALARMS SHALL BE INSTALLED IN THE FOLLOWING LOCATIONS:

1. Outside of each separate sleeping area in the immediate vicinity of the bedrooms.
2. On every level of a dwelling unit including basements.
3. Where a fuel-burning appliance is located within a bedroom or its attached bathroom, a carbon monoxide alarm shall be installed within the bedroom.

Smoke alarms and carbon monoxide alarms are permitted to be battery operated for existing areas of the building undergoing alterations or repairs, including reroofing, window replacement, siding, deck, porch or any work that requires a building permit.

IT IS REQUIRED AS ADOPTED UNDER THE CITY OF MILLBRAE MUNICIPAL CODE TO INSTALL SMOKE AND CARBON MONOXIDE ALARMS FOR A FINAL INSPECTION.

I hereby certify under penalty of perjury that I have installed and tested, or have had an individual under my direction, install and test all smoke alarms and carbon monoxide alarms for the address and permit number listed above. I further attest that all smoke alarms and carbon monoxide alarms are installed and working at the required locations.

Building Address

Permit Number

Print Name (Property Owner or Contractor)

Date

Signature