



**2016 CALIFORNIA RESIDENTIAL CODE
SMOKE AND CARBON MONOXIDE ALARMS REQUIREMENTS**

SMOKE ALARMS R314

SMOKE ALARMS SHALL BE INSTALLED IN THE FOLLOWING LOCATIONS:

1. In each sleeping room.
2. Outside each separate sleeping area in the immediate vicinity of the bedrooms.
3. On each additional story of the dwelling, including basements, habitable attics, and uninhabitable attics.

CARBON MONOXIDE ALARMS R315

CARBON MONOXIDE ALARMS SHALL BE INSTALLED IN THE FOLLOWING LOCATIONS:

1. Outside of each separate sleeping area in the immediate vicinity of the bedrooms.
2. On every level of a dwelling unit including basements.

Smoke alarms and carbon monoxide alarms are permitted to be battery operated.

PLEASE INSTALL THE FOLLOWING SMOKE AND CARBON MONOXIDE ALARMS FOR A FINAL INSPECTION. This form shall be completed and provided to the Building Inspector for any permit that is related to work at the exterior of the building only, such as re-roofs, sewer, retaining wall, etc.

PROPERTY OWNER SMOKE ALARM AND CARBON MONOXIDE ALARM CERTIFICATION

Building Address

Permit Number

I hereby certify that I have installed and tested, or have had an individual under my direction, install and test all smoke alarms and carbon monoxide alarms for the address and permit number listed above. I further attest that all smoke alarms and carbon monoxide alarms are installed and working at the required locations.

Print Name (Property Owner or Contractor)

Date

Signature

September 2017